



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL ZONAL LABORATORY (SOUTH)
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QML-8004290 IS/ISO 9001:2015



Ref. A.C.W.A.(South):-Paid/2023-24/P83-84/Challan no 358 Dt 21.11.2023 S. No 8093 Date: 05.12.2023

M/S GURU NANAK GARIB NIWAJ EDUCATION SCHOOL
NANAKSAR COMPLEX, GURUDWARA ROAD, M-BLOCK, GREATER KAILASH-II
NEW DELHI-110048

Date of Sample collection :- 01.12.2023

S.No	Characteristics	Unit	Acceptable Limit	Permissible Limit	Test Method	SYNTEX TANK ON KITCHEN ROOF	DRINKING POINT NEAR KITCHEN
1.	Clarity	Unit	5	15	IS 3025 Part-4	Clear	Clear
2.	Odour	—	Agreeable	Agreeable	IS 3025 Part-5	Agreeable	Agreeable
3.	Turbidity	NTU	1	5	IS 3025 Part-10	2.22	0.89
4.	pH Value	—	6.5-8.5	No relaxation	IS 3025 Part-11	7.4	7.4
5.	Conductivity	µmho/cm ¹	—	—	—	288	372
6.	Total Dissolved Solids	mg/L	500	2000	IS 3025 Part-16	187	242
1.	Phenolphthalein Alkalinity	mg/L	—	—	—	NIL	NIL
2.	Total Alkalinity (as CaCO ₃)	mg/L	200	600	IS 3025 Part-23	86	120
3.	Total Hardness (as CaCO ₃)	mg/L	200	600	IS 3025 Part-21	114	140
4.	Carbonate hardness	mg/L	—	—	—	86	120
5.	Non- Carbonate Hardness	mg/L	—	—	—	28	20
6.	Calcium Hardness	mg/L	—	—	—	80	96
7.	Magnesium Hardness	mg/L	—	—	—	34	44
8.	Ammonia (as Total N)	mg/L	0.5	No relaxation	IS 3025 Part-34	ND	ND
9.	Nitrite (as N)	mg/L	—	—	—	ND	ND
10.	Nitrate	Mg/L	—	45.0	IS 3025 Part-34	3.2	4.6
11.	Sulphate (as SO ₄)	mg/L	200	400	IS 3025 Part-24	38	38
12.	Chloride (as Cl)	mg/L	250	1000	IS 3025 Part-40	18	22
13.	Iron	Mg/l	—	1.0	IS 3025 Part-53	0.06	0.06
14.	Fluoride	mg/L	1.0	1.5	IS 3025 Part-60	0.16	0.36
15.	Calcium (as Ca)	mg/L	75	200	IS 3025 Part-57	32.0	23.04
16.	Magnesium (as Mg)	mg/L	30	100	IS 3025 Part-46	8.16	10.56
17.	Free Residual Chlorine	mg/L	0.2	1	IS 3025 Part-26	1.21	NIL

[Signature]
ACWA(SOUTH)

[Signature]
CHEMIST

[Signature]
ACHEMIST

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"


DELHI JAL BOARD

(GOVT. OF N.C.T. DELHI)


QUALITY CONTROL ZONAL LABORATORY (SOUTH)
WATER WORKS OKHLA DELHI-110025



Delhi Jal Board



Licence No- CRO/QML-8004290 IS/ISO 9001:2015



Dated:04.12.2023

No. DJB/DTQC/ CWA (W&S)III / ACWA (south)/ Bact/P.S./2023-2024/085-086/01.12.2023


Bacteriological Analysis Report as per IS 10500:2012


To M/s Guru Nanak Garib Niwaj Education School
Nanaksar Complex Gurudwara Road Greater
Kailash II
New Delhi -110048

Party Ref.No./Date: Nil
Deptt.Challan No. /date: 358/21.11.2023
Dt.of sample collection: 01.12.2023
No. of Sample: Two (02)
Collected by: Name- Ms Shweta Kirad
Desig.- Asstt Bacteriologist

SL.No.	Particulars	Clarity	Residual chlorine	Total coliform/ E.coli in 100 ml sample
1.	Syntex tank on roof of the kitchen	Clear	1.2	0
2.	Drinking point near kitchen	Clear	Nil	0

RESULT:- Collected water samples as mentioned above at Sr.No. 1, 2 were found bacteriologically satisfactory, hence the water/source is fit for drinking/recreational purpose subject to satisfactory attached Physical-Chemical Analysis report also.


Dr. D.P. Singh
ACWA (SOUTH)


BACTERIOLOGIST(SOUTH)


ASST/BACT.

MUNICIPAL CORPORATION OF DELHI
(Office of the Deputy Health Officer)
PUBLIC HEALTH DEPARTMENT, SOUTH ZONE
Green Park, New Delhi-110016
dhosouthzone@gmail.com

No. DHO/SZ/MCD/2023/D-3059

Dated: 12/12/23

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Bhoopender Kumar (Public Health Inspector) from Public Health Department, South Zone inspected the GURU NANAK GARIB NIWAJ EDUCATION SCHOOL Situated at Nanaksar Complex, Gurdwara Road, M-Block, Greater Kailash-II, New Delhi-110048 on 08-12-2023 and found that the GURU NANAK GARIB NIWAJ EDUCATION SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for one year from date of issue.

Deputy Health Officer

South Zone
Dr. Sanjay Sinha
Dy. Health Officer/SZ

Copy to:-

Ms. Meenakshi Malhotra (Principal)
GURU NANAK GARIB NIWAJ EDUCATION SCHOOL
Nanaksar Complex, Gurdwara Road,
M-Block, Greater Kailash-II, New Delhi-110048